

## Testing Report

Date 11 November 2022

Company Masons Plastabrick Ltd

### Products Tested

Supplied by Masons Plastabrick	Supplied by Soudal
• Roof Boot Flashing 110-170mm Red Silicone	• Gorilla MS Sealant
• Roof Boot Flashing 110-170mm Black EPDM Rubber	• Gorilla Roofers Silicone

### Purpose of testing:

- Determine adhesion of Soudal products to the Roof Boot Flashing's as supplied by Mason Plastabrick Ltd products.

### Conclusion

- While sealing to both "Roof Boot Flashing's" was achieved by both Soudal products the slightly better adhesion was achieved using the Gorilla Roofers Silicone.
- It is important that the surfaces are clean, dry & dust free. There is a slight improvement in adhesion for both sealants when the surface to be bonded has been wiped with a solvent cleaner

## Testing Outcomes

	Gorilla MS Sealant	Gorilla Roofers Silicone
Roof Boot Flashing 110-170mm Black EPDM Rubber	Excellent Seal Very Good Adhesion PASS	Excellent Seal Very Good Adhesion PASS
Roof Boot Flashing 110-170mm Red Silicone	Excellent Seal Very Good Adhesion PASS	Excellent Seal Very Good Adhesion PASS

**Note:** Adhesion and Seal testing were assessed on the basis on the how the practical fixing of Roof Boot Flashings is fitted in accordance with MRM Code of Practicev3.0

Prepared by: Steve Loveridge  
Soudal Technical Manager  
11 November 2022

